



MEMORANDUM / STAFF REPORT:

To: Dan Ertl, Director of Community Development
Richard VanDerWal, Planning Administrator
Emily Zandt, Associate Planner
Natalie Schneider, Project Engineer
Jackie Quandt, Project Engineer

FROM: DAVID MASON, FIRE CHIEF

Date: JULY 11, 2023

Re: REVIEW OF WESTMOOR COUNTRY CLUB
INTERIOR RENOVATION AND DECK EXPANSION PLANS DATED 7.3.23

Please share the following with the project developers.

1. A fire sprinkler system shall be installed throughout and installed in accordance with NFPA 13 and City of Brookfield code 8.08.
2. Fire alarm system is required and shall be installed in accordance with NFPA 72 and City of Brookfield code 8.08.
3. Compliance with City of Brookfield code 8.08 Fire Prevention and Life Safety.